



THE CITY OF KEY WEST

Post Office Box 1409 Key West, FL 33041-1409 (305) 809-3700

Reference: City of Key West Ordinance & Fire Code Requirements for Grills

Key West, Florida, Code of Ordinances >> SUBPART A – GENERAL ORDINANCES >> Chapter 30 – FIRE PREVENTION AND PROTECTION >> ARTICILE III. REGULATIONS >>

Sec. 30-57. Adoption of fire prevention and life safety codes.

The most recent Life Safety Code (NFPA 1), (NFPA 101), published by the National Fire Protection Association; the Florida Fire Prevention Code, published by the National Fire Protection Association; and the Florida Building Code as adopted by the State of Florida, are adopted and made a part of the Code of Ordinances for the purpose of encouraging and regulating fire prevention and life safety within the city. A copy of each such standard code shall be on file for inspection in the office of the chief of the fire department during regular office hours.

(Code 1986, 31.118; Ord. No. 09-08, 1, 6-2-2009)

NFPA 1:10.11.6.1 (Life Safety Code)

For other than one- and two-family dwellings, no hibachi, grill, or other similar devices used for cooking, heating, or any other purpose, shall be used or kindled on any balcony, under any overhanging portion, or within 10 ft. (3m) of any structure.

NFPA 1:10.11.6.2 (Life Safety Code)

For other than one- and two-family dwellings, no hibachi, grill, or other similar devices used for cooking, heating, or any other purpose, shall be stored on a balcony.

NFPA 101:3.3.66.1 (Life Safety Code)

One- and Two-family Dwelling Unit. A building that contains not more than two dwelling units with independent cooking and bathroom facilities.

(NFPA 1, & NFPA 101 2012 Edition)

3266 LSN 132